

Notified Body
Nr. 0036



Industrie Service

Certificate of conformity of the factory production control

0036 CPR 91236 030
Revision 05

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

System chimney type PERMETER SMOOTH models

model 1, 5, 9, 13,		
model 17, 18, 19, 20	EN 1856-1	T600 N1 D VX LXX050 G75
model 2, 6, 10, 14	EN 1856-1	T450 N1 D VX LXX050 G60
model 3, 7, 11, 15	EN 1856-1	T450 N1 D VX LXX050 G50
model 4, 8, 12, 16	EN 1856-1	T600 N1 D VX LXX050 G25

for details of classification see page 2

produced by

Schiedel s.r.o.
Horoušanská 286
25081 Nehvizdy, CZECH REPUBLIC

in the manufacturing plants

Schiedel s.r.o.
Modlanská 1
41502 Teplice
Czech Republic

Schiedel Sp. Z o.o.
Okup Wielki, Ul. Inwestycyjna 13
98-100 Łask
Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 1856-1:2009

under system 2+ are applied and that the factory production control fulfils all the prescribed requirements set out above.

The determination of the product type on the basis of type testing is documented.

This certificate was first issued on 2007-06-06 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Munich, 2024-03-25

Johannes Steiglechner
Leiter Zertifizierungsstelle Bauprodukte



System chimney Perimeter Smooth	EN 1856-1
model 1	
DN 130 – DN 200	T600 N1 D V2 L50050 G75
model 2	
DN 130 – DN 200	T450 N1 D V2 L50050 G60
model 3	
DN 130 – DN 200	T450 N1 D V2 L50050 G50
model 4	
DN 130 – DN 200	T600 N1 D V2 L50050 G25*
model 5	
DN 130 – DN 200	T600 N1 D V2 L99050 G75
model 6	
DN 130 – DN 200	T450 N1 D V2 L99050 G60
model 7	
DN 130 – DN 200	T450 N1 D V2 L99050 G50
model 8	
DN 130 – DN 200	T600 N1 D V2 L99050 G25*
model 9	
DN 130 – DN 200	T600 N1 D Vm L20050 G75
model 10	
DN 130 – DN 200	T450 N1 D Vm L20050 G60
model 11	
DN 130 – DN 200	T450 N1 D Vm L20050 G50
model 12	
DN 130 – DN 200	T600 N1 D Vm L20050 G25*
model 13	
DN 130 – DN 200	T600 N1 D V3 L50050 G75
model 14	
DN 130 – DN 200	T450 N1 D V3 L50050 G60
model 15	
DN 130 – DN 200	T450 N1 D V3 L50050 G50
model 16	
DN 130 – DN 200	T600 N1 D V3 L50050 G25*
model 17	
DN 130 – DN 200	T600 N1 D V2 L50050 G75**
model 18	
DN 130 – DN 200	T600 N1 D V2 L99050 G75**
model 19	
DN 130 – DN 200	T600 N1 D Vm L20050 G75**
model 20	
DN 130 – DN 200	T600 N1 D V3 L50050 G75**

* = system chimney with 50 mm insulation

** = system chimney with 50 mm insulation, tested in a configuration according to EN 13216-1: 2019 with test wall thickness WC600, no enclosure E0 test floor thicknesses F1C200 and F2C600, completely closed and insulated floor penetrations F1P2C and F2P2C